

कार्यालय सहायक यंत्री लोक स्वास्थ्य यांत्रिकी उपखण्ड
बालाघाट

क्रमांक २३११/लेब./लो.स्वा.यां./उपखण्ड,
प्रति,


बालाघाट दिनांक २०/०९/२०१९

ग्रीनवेली पब्लिक स्कूल,
ग्राम डोंगरिया, पोस्ट चिल्लोद,
तहसील लालबर्वा जिला बालाघाट

विषय:- जल परीक्षण रिपोर्ट देने बाबद।
संदर्भ:- आपका पत्र क्रमांक जीवीपीएस/२०१९-२०/एएफएफ/एफ १/४४१ दिनांक ११.०९.२०१९
—००—

उपरोक्त विषयांतर्गत लेख है, कि आपके द्वारा भेजे गये जल नमूनों का परीक्षण कर रिपोर्ट पत्र के साथ संलग्न कर आपकी ओर प्रेषित है।

सहपत्र:- जल परीक्षण रिपोर्ट की सूची।


सहायक यंत्री
लोक स्वास्थ्य यांत्रिकी उपखण्ड
बालाघाट


Principal
Green Valley Public School
Balaghat (M.P.)

WATER ANALYSIS LABORATORY (T.M.)
P.H.E. SUB DIVISION BALAGHAT, Disst. BALAGHAT

11.00AM

(1) SAMPLE RECEIVED ON DATE 11.09.2019

(2) DATE OF ANALYSIS 16.09.2019

S.No.	Characterist	Units	Requirement of Human Body (Desirable limit)	Cause of Rejection (Permissible Limit) In absence of Alternate Source	ग्रीनवेली पब्लिक स्कूल ग्राम डोंगरिया
1	Turbidity	N.T.U.	1.0	5.0	2.7
2	Color	Pletiniam, Cobald, Schel	5	15	5
3	P.H. Value	PH Scale	6.5 to 8.5	No Relaxation	6.2
4	Test of odour	-	Nothing	Disgreeable	Nothing
5	Chloride	PPM	250	1000	40
6	Conductivity	—, —	Milimos	Micromos	240.2
7	Totel Dissolved solids	—, —	500	2000	122.4
8	Totel Alkalinity	—, —	200	600	240
9	Total Hardness	—, —	200	600	300
10	Calcium Hardness	—, —	75	200	58.50
11	Magnicium Hardness	—, —	30	100	36.00
12	Sulphate	—, —	200	400	58.54
13	Iron	—, —	0.3	1.0	Nill
14	Flouride	—, —	1.0	1.5	0.1
15	Nitrate	—, —	45	45	Nill
16	Residul Chlorine	—, —	0.2	1.0	Nill
17	Fical Coliform	—, —	0	0	Nill

सहायक यंत्री
लोक स्वास्थ्य मंत्रिकी उपखण्ड
बालाघाट


Principal
Green Valley Public School
Balaghat (M.P.)

APPENDIX - VIII

PROFORMA REGARDING SANITARY CONDITION CERTIFICATE

No. 5731

Date - 11/12/2013

It is certified that an inspection team headed by S. Shailesh Kumar
Deshnaya, District Programme Manager (Name of
Officers with designation) from Balaghat inspected the **Green Valley**
Public School, Dongariya, Balaghat on date 10/12/2013 and found that the **Green**
Valley Public School, Dongariya, Balaghat is maintaining the hygienic sanitation condition in
the school building & the campus as per the norms prescribed by the State Govt.

The above valid for a period of One Year (2014-15)

Signature with Seal :

Name :

Designation :

Dr. Pooresh Upadhyay
District Programme Manager

Office. BGF

To

The principal
Green Valley Public School,
Dongariya, Balaghat
(M.P.) 481001

Principal
Green Valley Public School
Balaghat (M.P.)